

APPENDIX 5

WASTEWATER FLOW PEAKING FACTORS

AVERAGE FLOW (MGD)	PEAK FACTOR
0 - .10	3.00
.101 - .20	2.95
.201 - .30	2.90
.301 - .40	2.85
.401 - .50	2.80
.501 - .60	2.75
.601 - .70	2.70
.701 - .80	2.65
.801 - .90	2.60
.901 - 1.0	2.55
1.01 - 2.0	2.50
2.01 - 4.0	2.25
>4.0	2.00