



BOARD OF COUNTY COMMISSIONERS  
 Kevin Beckner  
 Victor D. Crist  
 Ken Hagan  
 Al Higginbotham  
 Lesley "Les" Miller, Jr.  
 Sandra L. Murman  
 Mark Sharpe

Office of the County Administrator  
 Michael S. Merrill

CHIEF ADMINISTRATIVE OFFICER  
 Helene Marks  
 CHIEF FINANCIAL ADMINISTRATOR  
 Bonnie M. Wise  
 DEPUTY COUNTY ADMINISTRATORS  
 Lucia E. Garsys  
 Sharon D. Subadan

**Seaboard PWS 6290333 - This report includes data collected from January 1 through December 31, 2010**

Dear Customer: Although you are a customer of the Hillsborough County Public Utilities Department, drinking water for your community has been provided by the City of Tampa since September 2007. Included is a report from the City of Tampa that provides you with information on the quality of their water provided to you in 2010. In addition to the monitoring done by the City, Hillsborough County monitors the water in your subdivision for total coliform bacteria, lead, copper, and disinfection by-products. The following table summarizes the levels of these contaminants if detected in your water:

**Microbiological Contaminants**

Contaminant and Unit of Measurement	Dates of Sampling	MCL Violation	Highest Monthly Number of Positive Samples	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	Feb 2010	No	1	0	Presence of coliform bacteria in 1 sample collected during any month	Naturally present in the environment

**Stage 1 Disinfectants and Disinfection By-Products**

Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling	MCL or MRDL Violation	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chloramines (ppm)	Jan-Dec 2010	No	2.8	1.6 - 4.1	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	Quarterly 2010	No	15.3	ND - 26.8	N/A	MCL = 60	By-product of drinking water disinfection
TTHM (Total trihalomethanes) (ppb)	Quarterly 2010	No	43.5	5.61 - 62.5	N/A	MCL=80	By-product of drinking water disinfection

**Lead and Copper (Tap Water)**

Contaminant and Unit of Measurement	Dates of Sampling	Action Level Exceeded	90 <sup>th</sup> Percentile Result	Number of Sampling Sites Exceeding the Action Level	MCLG	Action Level	Likely Source of Contamination
Copper (Tap Water) (ppm)	Jul-Sep 2008	No	0.374	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	Jul-Sep 2008	No	1.556	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

For an explanation of the abbreviations used in the above table, please refer to the water quality report included in this mailing. If you have any questions regarding the monitoring Hillsborough County performs on your water, please contact our Environmental Laboratory at (813) 264-3887. If you have other water quality questions or concerns, the included report from the Tampa Water Department provides additional contact information. Hillsborough County Public Utilities Department Customer Service, at (813) 272-6680, can answer questions you may have about your bill. If you have a water quality complaint, call (813) 264-3835. For an after-hours water-related emergency, call (813) 744-5600. We urge all our customers to use this precious resource wisely to preserve it for present and future generations.